



OFFICE OF THE CHEMIST

PUBLIC HEALTH ENGINEERING DEPARTMENT DRINKING WATER TESTING LABORATORY, PALWAL
9MLD STP, JODHPUR ROAD, PALWAL, HARYANA - 121102



E-mail:-chemist.palwal@phedharyana.gov.in, chemist.palwal@gmail.com

TC-4091

TEST REPORT

Issued to : → Apollo Progressive Convent School	Location: → Ronija, Palwal
Test Report No. : → PWL/01402/7/2024	Collected by: → Raju
Reference No. : → /dt. 01/07/2024	Sample collected Date & Time : → 02/07/2024 at 09:00
Sample Type : → R.O.	Sample received Date & Time : → 02/07/2024 at 09:30
Test Type : → Chemical Test	Date of Analysis Started : → 02/07/2024
Classification of Sample : → Private	Date of Analysis Completed : → 02/07/2024
Sample Description : → Water Sample Received in food grade plastic bottle at room temperature	Sample Quantity : → 1000 ml
Lab Job Order No.: → V-333	Issue Date of Report: → 02/07/2024
	Addition/Deviation/ Exclusions from the method : NA

Test Result

Sr. No.	Tested Parameter	Results	Unit	Method	As per IS 10500:2012 RA 2018	
					Acceptable	Permissible Limit
1.	Turbidity	<1	NTU	APHA 24th Edition-2130-B	1 NTU	5 NTU
2.	Taste	Agreeable		IS 3025 (Part-8)1984:RA 2023	Agreeable	Agreeable
3.	Odour	Agreeable		IS 3025 (Part-5) 1983:2018	Agreeable	Agreeable
4.	Colour	<5	CU	APHA 24th Edition-2120 - B	5 CU	15 CU
5.	Total Dissolve Solids (180°C ± 2°C)	250	mg/l	APHA 24th Edition-2540 C	500 mg/l	2000 mg/l
6.	Total Hardness as CaCO ₃	70	mg/l	APHA 24th Edition-2340 C	200 mg/l	600 mg/l
7.	Calcium as (Ca)	13.62	mg/l	APHA 24th Edition-3500-Ca B	75 mg/l	200 mg/l
8.	Magnesium (Mg)	8.74	mg/l	APHA 24th Edition-3500Mg B	30 mg/l	100 mg/l
9.	Total Alkalinity	50	mg/l	APHA 24th Edition-2320 B	200 mg/l	600 mg/l
10.	Chlorides as Cl	55.98	mg/l	APHA 24th Edition-4500 Cl- B	250 mg/l	1000 mg/l
11.	Sulphate as (SO ₄)	15	mg/l	APHA 24th Edition-4500-So ₄ ²⁻ E	200 mg/l	400 mg/l
12.	Fluoride as (F)	0.21	mg/l	APHA 24th Edition-4500-F ⁻ D	1.0 mg/l	1.5 mg/l
13.	Iron as (Fe)	0.01	mg/l	APHA 24th Edition-3500-Fe B	1.0 mg/l	No Relaxation
14.	Nitrate as (NO ₃)	4.1	mg/l	APHA 24th Edition-4500-No ₃ · D	45 mg/l	No Relaxation
15.	pH (@25°C)	6.97	---	APHA 24th Edition-4500-H ⁺ B	6.5-8.5	No Relaxation

Remarks: -

Specific contractual notes: -

- ♦ The results given above are related to the sample as received and tested in PHED Lab PALWAL.
- ♦ The test report can't be regenerated/ re-produced in whole or part thereof without written permission of PHED Lab PALWAL.
- ♦ The test report can't be used for any publicity or any legal purpose.
- ♦ Reliability of water sample lies with sender/collector of water sample.

Priya Rawat
President
Priya Rawat Shiksha Samiti
New Extn. Colony, Palwal-121102

END OF REPORT

Water is Life, Don't Waste It

CHEMIST (RENA)
PUBLIC HEALTH ENGINEERING DEPARTMENT
WATER TESTING LABORATORY
PALWAL

Attache

Kanits
Principal 14/7/24

Apollo Progressive Convent School
RCA (Palwal) - 121102
PHED/PWL-8F-01


Health & Hygiene Certificate

Ref. No. CS/Pwl/2024/Snn/199


Dated. 12/04/2024


In pursuance of the application of Apollo Progressive Convent School, Rasulpur road, Ronija, Palwal (Haryana) in the O/o Civil Surgeon Palwal. The School premises were inspected by team of Health Department O/o Civil Surgeon, Palwal on dated 09-02-2024. The School was found to have satisfactory hygiene conditions as per the standard checklist of the district. This certificate is valid up to 31-03-2025


Date of Renewal:- 01-04-2025




Dy. Civil Surgeon (School Health)
Palwal


Civil Surgeon
Palwal




President
Priya Rawat Shiksha Samiti
New Extn. Colony, Palwal-121102


Principal 12/04/24
Apollo Progressive Convent School
RONIJA (Palwal) - 121102